

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE 1 OF 4 PAGES	
2. AMENDMENT/MODIFICATION NO. 03		3. EFFECTIVE DATE 08/23/2007		4. REQUISITION/PURCHASE REQ. NO. HB 070118		5A. TITLE: Construct E85 Fuel Pumping Station	
						5B. PROJECT NO.	
6. ISSUED BY		CODE		9901		7. ADMINISTERED BY (If other than Item 6)	
AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515						AOC - Procurement Division 2nd & D Streets, SW ATTN: Fred Witcher Room H2-263 WASHINGTON, DC 20515	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code)						(X)	
						9A. AMENDMENT OF SOLICITATION NO. RFP070117	
						X	
						9B. DATED (SEE ITEM 11) 07/26/2007	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 11)	
CODE		FACILITY CODE					

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended,

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 7 and 14, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)
SEE LINE ITEMS

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
This amendment is issued to answer contractor questions and provide a copy of attendee sheet from the initial site visit.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		BY _____	
		(Signature of Contracting Officer)	

NSN 7540-01-152-8070
Previous edition unusable

STANDARD FORM 30 (REV. 10-83)
Prescribed by GSA FAR (48 CFR) 53.243

RFP070117

Summary Info Continuation Page1

QUESTIONS AND RESPONSES

1. Question: Make / Model and possibly serial number for the PetroVend Card reader system and how it is set up.

Response: This information will be provided after award of contract.

2. Question: Does it use cards, keys or user input or a combination of cards, keys and user input?

Response: The Petrovend system uses "virtual cards". Account users are given a four digit number that is within the parameters of their assigned account. They then have to create a PIN to be able to access the pumps.

3. Question: How many vehicles are assigned for use?

Response: There are 1000 spaces available within Petrovend.

4. Question: Do you want the same interface with the new dispenser?

Response: Yes.

5. Question: How many vehicles will be authorized for the new dispenser?

Response: We anticipate the use of this station by approximately 200 vehicles. See Part 3, Paragraph 2.2.1 of the RFP.

6. Question: Will AOC do the programming or will we be required to input the data?

Response: The AOC will be maintaining the Petrovend system due to constant changes within the workforce and who is authorized to pump fuel at our facility.

7. Question: Can we use the existing Veeder Root TLS 350 to monitor the new tank as well as the existing tank (The 350 is capable of monitoring up to 16 tanks so 2 does not limit future expansion capabilities)? If yes, can we get a copy of the Veeder Root TLS-350 Underground Tank Monitoring System O&M Manual.

Response: Yes, the new tank shall be monitored by the existing Veeder Root System. A copy of the manual will be provided after award of contract.

8. Question: Are there As Built drawings available for the previous excavation? If so, can we get a copy of the existing fuel station Contract Drawings and Specs, so that we can review the existing conditions and wiring. In particular we would like to know:

a) How is the Petrovend wired to the existing dispenser?

As-built drawings will be provided after award of contract.

b) How is the Veeder Root Wired?

This information will be provided after award of contract.

c) Did they use sheeting/shoring before? Is it still in place?

Yes, shoring was used but removed after completion of construction.

d) What type of tank is currently in the ground? Fiberglass or other?

Fiberglass (4000 gallon) as indicated in RFP.

THE FINAL SITE VISIT IS BEEN SCHEDULED FOR 24 AUG 07, 10:00 A.M. WE WILL MEET AT 14 E STREET, S.E. - BETWEEN NEW JERSEY AVENUE, S.E. AND S. CAPITOL STREET, S.E. CONTACT MR. FRED WITCHER AT (202) 226-7092 FOR ADDITIONAL INFORMATION.

THE DUE DATE AND TIME FOR RECIPT OF PROPOSALS REMAINS 4 SEP 07, 1:00 P.M.

BASE

Number	Commodity Name	Quantity	Unit of Issue	Unit Price (\$)	Total Cost (\$, Inc. disc)
1	Base Bid	Total : 1.00	JB	\$	\$
Description: Construct an E85 Pumping Station fed by a new 10,000 gallon double-walled fiberglass underground storage tank, new pumping islands, connection to the existing monitoring and accounting system, site lighting, pavement and curb cuts and required containment systems.					

Lump-Sum Price for Base

\$

OPTION 1

Number	Commodity Name	Quantity	Unit of Issue	Unit Price (\$)	Total Cost (\$, Inc. disc)
2	Option No. 1	Total : 1.00	JB	\$	\$
Description: Install a new pump for the existing gasoline fuel system underground, in, at or near the gasoline fuel tank. Gasoline pump shall be configured in a similar manner to the E85 fuel pump.					

Lump-Sum Price for Option 1

\$

OPTION 2

Number	Commodity Name	Quantity	Unit of Issue	Unit Price (\$)	Total Cost (\$, Inc. disc)
3	Option No. 2	Total : 1.00	JB	\$	\$

Description: Provide a sustainable design feature related to the addition of lighting to the station by incorporating photo voltaic (PV) system on the roof of the garage that feeds a battery backup system sized to provide 12 hours of continuously powered lights at the pumping station.

Lump-Sum Price for Option 2

\$

Lump-Sum Price for All Options

\$

Lump-Sum Price for Base and All Options

\$

RFP 070117, Construct E85 Fuel Pumping Station,
Washington DC

SITE VISIT LIST OF ATTENDEES

Wednesday, August 15, 2007

10:00 a.m.

PLEASE PRINT PLEASE PRINT PLEASE PRINT

<u>Name of Representative</u>	<u>Company Name and Address</u>	<u>Telephone & FAX Numbers</u>
JOHN E Walser	O'Brien & Gere 12625 Izaak Walton Rd Bristow, VA 20136	(703) 622-8093 ()
Carl D Johnson	O'Brien & Gere 8401 Corporate Dr. Suite 400 Landover, MD 20785	(301) 781-1158 ()
PAUL RICHARDS	AOC FPE PHOB 543B	(202) 226-1049 ()
	AOC CAPITOL GROUNDS	(202) 224-3069 ()
GLENN MARSHAL		
WAYNE WEST	AOC CAPITOL GROUNDS GENERAL SUPERVISOR	(202) 544-6269 CELL (202) 369-6936
		()
		()
		()
		()
		()
		()
		()
		()